

Fire protection paint Protega Novatherm 1FR/ Protega Top 1FR ECO

Holder/Issued to

Protega AB

Verkstadsgatan 6B, SE-231 66 Trelleborg, Sweden
Organisation number/VAT number: 556326-7987
Phone: 046 410-567 80, E-mail: info@protega.se, Web: www.protega.se

Product description

Protega fire protection paint system consisting of Protega Novatherm 1FR and Protega Top 1FR ECO. Amount of paint (wet weight) Protega Novatherm 1FR, 300 g/m² and 60 g/m², Protega Top 1FR ECO. Paint system for application onto wood based substrates at least 8 mm thick, having density ≥ 338 kg/m³ and any substrate having fire class A1 or A2-s1, d0 with minimum thickness 6 mm and density ≥ 338 kg/m³.

Intended use

Paint work of walls and ceilings inside buildings

Trade name

Protega Novatherm 1FR/Protega Top 1FR ECO and Potega Novatherm 1FR/Protega Top 1FR

Approval

The products satisfy the requirements set forth in chapter 8, 4 § 2 PBL, in respect to and under conditions stated in this certificate, and are therefore approved in accordance with the provisions of the following sections of Boverket Building Regulations (BBR):

Raaction to fire class according to EN 13501-1

5:521, 5:522 and 5:523

Associated documents

Protega, product data sheet for Protega Novatherm 1FR, dated 2021.05.

Protega, product data sheet for Protega Top 1FR ECO, dated 2021.05.

Control

The factory production control (FPC) is monitored by an independent inspection body.

Control agreement: Ref no. 210-97-0677, Inspection body: RISE Research Institutes of Sweden AB

When the building proprietor performs inspection at the building site, markings shall be checked to ensure that the correct products have been supplied and that they are used in accordance with the conditions in this approval and associated documents. Further the product shall be accompanied by a manufacturer's assurance, certifying that the product has been manufactured in accordance with the documents on which this approval is based.

Manufacturing place

Production control includes the following place:
Protega AB, Trelleborg

Marking

The products are to be marked at the factory. The marking consists of a label on every packing supplied and includes:

Holder/ Manufacturing place	Protega AB, Trelleborg
Product type designation	e.g. Protega Novatherm 1FR
Consecutive manufacture no./date of production	no/date
Type approval number	0086/99
Properties	B-s1, d0
Boverket's registered trade mark	†
RISE Accreditation number	1002
Certification body and Inspection body	RISE

Basis for assessment/approval

Report 5P08305 and classification report PX08305-1rev1 from SP Technical Research Institute of Sweden.

Comments

This approval supersedes the previous approval with the same number dated 2021-05-09.

Validity

Valid through 2026-05-08.

The validity of this approval expires when the characteristics included in this approval shall be CE-marked according to the Construction Products Regulation (EU) 305/2011.

Martin Tillander

This is a translation from the Swedish original document. In the event of any dispute as to its content, the Swedish text shall take precedence